

## ENERGY RELATED PRODUCT DIRECTIVE

This product meets the Ecodesign Requirements for an electric fixed local space heater.  
Commission regulation (EU)2015/1188

Model Identifier(s):		QRAD 050E	QRAD 075E	QRAD 100E	QRAD 150E	QRAD 200E	Unit
<b>Heat output</b>							
Nominal heat output	P <sub>nom</sub>	0.50	0.75	1.00	1.50	2.00	kW
Minimum heat output (indicative)	P <sub>min</sub>	0.00	0.00	0.00	0.00	0.00	kW
Maximum continuous heat output	P <sub>max,c</sub>	0.50	0.75	1.00	1.50	2.00	kW

<b>Auxiliary electricity consumption</b>							
At Nominal heat output	e <sub>lmax</sub>	0.00	0.00	0.00	0.00	0.00	kW
At Minimum heat output	e <sub>lmin</sub>	0.00	0.00	0.00	0.00	0.00	kW
In Standby Mode	e <sub>lSB</sub>	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	kW

<b>Type of heat output / room temperature control</b>	
With electronic room temperature control plus week timer	Yes
Room temperature control with open window detection	Yes
With adaptive start control	Yes

### Contact details:

Glen Dimplex Heating and Ventilation

Millbrook House, Grange Drive, Hedge End, Southampton, SO30 2DF

TEL: 0344 879 3588